



AWP & MEWP Crane Supported Work Platforms– WELL Sheet (Arial Work Platform & Mobile Elevated Work Platform)

WELL Sheet #: 1001
Revision: 2021/11

Date:		Job:		:		
Observation team member:				Signature:		
Observation team member:				Signature:		
Observation team member:				Signature:		
Location of Work:				Yes	No	N/A
1.	Operators hold a valid (3 years) training certificate for the specific model and type of AWP / MEWP (Arial Work Platform/ mobile Elevated Work Platform).					
2.	The MEWP is only moved on level ground with boom retracted and/or lowered position.					
3.	All employees working in the AWP / MEWP are properly "tied off".					
4.	The capacity of the equipment is known by the operator and is not exceeded.					
5.	AWP / MEWP are used only for personnel and tools required to perform the work.					
6.	Pre-shift inspection is completed.					
7.	Crane supported work platforms are used only when other means of access to the work are extremely hazardous or not possible because of structural design or work site conditions.					
8.	Crane in use with the work platform is equipped with a positive load lowering system (eliminating the potential for free-fall) and is equipped with a functional anti two-block device. Any time a crane is being utilized to hoist a workbasket (or any load), the crane operator is in the seat, in control, with the engine running. "Safe Working Load" is not exceeded.					
9.	Manufacturer's instructions are available inclusive of the engineered design of the crane supported work platform. The platform is plated with the manufacturer, load rating, and date of last inspection (annual NDT)					
10.	Test lifts ("dry runs" of entire lift radius) are made prior to use and at each new setup location.					
11.	The use of the crane supported work platform has acquired approval from the Project Manager and the HSE Representative. In addition, a Job Safety Analysis (JSA), and a Safe Lift Plan have been completed.					
	NOTE: Consult with Total Health & Safety (Safety Specialist) and/or other SME(s) as necessary to verify these criteria.					
Comments:						