

### **S-99 Reports for 2009**

In accordance with regulatory document entitled S-99 Reporting Requirements for Operating Nuclear Power Plants, power reactors operating in Canada must issue formal reports to the Canadian Nuclear Safety Commission (CNSC) on events defined in the S-99 regulatory guideline document.

The following is a list of S-99 – Event Reports – that were generated for NB Power Nuclear -- Point Lepreau Generating Station operations in 2009.

NB Power Nuclear provides an update to this list on a quarterly basis.

### **Significant Development Reports**

In some instances S-99 events are the subject of Significant Development Reports and are presented by CNSC staff to the CNSC Commission at a public meeting. These events are typically ones which have higher potential. Significance or that may raise public interest. Those S-99 events which were Significant Development Reports will be highlighted in blue in the S-99 event listing.

### **Questions?**

For more information on the Event Reports listed, Event Reports from prior years or other reports on NB Power Nuclear's operations, contact **Kathleen Duguay, Manager of Public Affairs** at 506-659-6433.

### **Point Lepreau Generating Station 2009 S-99 Reporting (January to December 2009)**

<b>Event Number</b>	<b>Description</b>
ERD-79140-0901-029-A-00	Primary Heat Transport Water Leakage from 7914-TK2
ERD-71400-0902-003-A-00	Fire Protection
ERD-21601-0902-013-A-00	Late Reporting of a Missed Mandatory Test
ERD-71400-0902-013-A-00	Fire Protection System Piping Found Supporting Non-System Components
ERD-30100-0902-023-A-00	Safeguard Equipment Inadvertently Shutdown
ERD-03400-0902-025-A-00	Unplanned Exposure While Handling Pressure Tube Waste Container
ERD-03400-0903-011-A-00	Cigarette Butts and Ashes Found in Dousing Tank
ERD-71310-0904-002-A-00	Raw Service Water System Piping Found Degraded
ERD-71400-0904-030-A-00	Fire Protection System Piping Found Supporting Non-System Components
ERD-60210-0905-005-A-00	Unapproved Modifications to the Public Address System
ERD-67874-0905-006-A-00	Whole Body Monitor Damage
ERD-73140-0905-013-A-00	Unapproved Modification to the Containment System

ERD-71400-0906-017-A-00	Fire Alert Declared
ERD-60210-0907-003-A-00	Unapproved Modifications to the Public Address System
ERI-01962-0907-008-A-00	Potential for Workers to Inadvertently Contact Energized Crane Busbars
ERD-71400-0908-019-A-00	Two Fire Protection Zones Unnecessarily Selected to "Local" Control
ERD-34310-0909-030-A-00	Nitrile U-Ring Seals Found in Dousing Valve Actuators
ERD-60210-0910-014-A-00	Unapproved Modifications to the Public Address System
ERD-68230-0910-020-A-00	Missing Environmentally Qualified (EQ) Splices on Shutdown Safety System Number One (SDS1)
ERD-71400-0911-027-A-00	Fire Alert Declared in R/B East Vault
ERD-71400-0912-011-A-00	Fire Suppression System Piping Found Supporting Non-System Components
ERD-78600-0912-016-A-00	Fire Alert Declared in Outbuilding